

**ETL SEMKO**

VERIFICATION OF LISTING

ISSUED: May 5, 2005

ISSUED TO: **CURRIES Division of AADG, Inc.**
525 9th Street S.E.
Mason City, IA 50401

REPORT REFERENCES: J98021012-231; J98023595-231

This is to certify that representative assemblies of:

POLYSTYRENE CORE SWINGING TYPE FIRE DOORS, MODEL 607

have been investigated by Intertek-Warnock Hersey and have been found to be in compliance with the standard(s) indicated on this certificate:

Standards:

UL 10C (1998) "Standard for Positive Pressure Fire Tests of Door Assemblies"

UBC 7-2-1997 (Part 1) "Fire Tests of Door Assemblies"

BS 476

NFPA 252-1995

UL 10B (1997)

ASTM E152-81a

CAN4-S104-1980 (R1985)

Additional Information:


20, 18, or 16 gauge 4'0" x 7'0" single swing doors, 8'0" x 7'0" pairs of doors swinging in the same direction, and 6'0" x 7'0" pairs of doors swinging in the opposite direction (double egress) rated up to and including 3 hours. **No intumescent material required.**

Listed mortise or cylindrical locks and rim or mortise panic devices may be used with single swing doors. Listed mortise locks, cylindrical locks, mortise panics, surface mounted vertical rod exit devices, and surface mounted flush bolts may be used on pairs of doors. Rim exit devices with listed hardware or hollow metal mullion may be used on pairs of doors. 24" x 24" louvers and 48" x 48" metal kick plates may be used. Curries or listed vision light kits may be installed.

Pairs with 3 hour ratings must have either Z astragal or a flat astragal. An astragal is optional for pairs with 20 minutes, 3/4, 1, and 1-1/2 hour ratings. See Figures Flat Astragal with Optional Hardware Reinforcing, and "Z" Astragal with Optional Hardware Reinforcing.

Only those products bearing the Warnock Hersey registered certification mark should be considered as being covered by the Intertek – Warnock Hersey Listing and Follow-Up Service.

By:



Rick Curkeet, Chief Engineer
Intertek, Building Products Group

Intertek Testing Services NA, Inc.
8431 Murphy Drive, Middleton, WI 53562
Telephone: 608-836-4400 Fax: 608-836-0050
Web: www.intertek-etisemko.com