

**ETL SEMKO**

VERIFICATION OF LISTING

ISSUED: May 5, 2005

ISSUED TO: **CURRIES Division of AADG, Inc.**
525 9th Street S.E.
Mason City, IA 50401

REPORT REFERENCES: J98021012-231

This is to certify that representative assemblies of:

STEEL STIFFENED SWINGING TYPE FIRE DOORS, MODEL 747

have been investigated by Intertek-Warnock Hersey and have been found to be in compliance with the standard(s) indicated on this certificate:

Standards:

UL 10C (1998) "Standard for Positive Pressure Fire Tests of Door Assemblies"
UBC 7-2-1997 (Part 1) "Fire Tests of Door Assemblies"
BS 476
NFPA 252-1995
UL 10B (1997)
ASTM E152-81a
CAN4-S104-1980 (R1985)

Additional Information:

18, 16, or 14 gauge 4'0" x 10'0" single swing doors, 8'0" x 10'0" pairs of doors swinging in the same direction or swinging in the opposite direction (double egress) rated up to and including 1-1/2 hours. 18, 16, or 14 gauge 4'0" x 8'0" single swing doors and 8'0" x 8'0" pairs of doors swinging in the same direction or swinging in the opposite direction (double egress) rated up to and including 3 hours. 18 or 16 gauge 4'0" x 10'0" single swing doors and 8'0" x 10'0" pairs of doors swinging in the same direction or swinging in the opposite direction (double egress) rated up to and including 3 hours. 18 or 16 gauge 3'6" x 7'2" Dutch door rated up to and including 3 hours. **No intumescent material required.**

Listed mortise or cylindrical locks and rim or mortise panic devices may be used with single swing doors. Listed mortise locks, cylindrical locks, mortise panics, surface vertical rod devices, and surface bolts may be used on pairs of doors. Rim exits with listed hardware or hollow metal mullion may be used on pairs of doors. 48" x 48" metal kick plates may be used. Curries or listed vision light kits may be installed.

Only those products bearing the Warnock Hersey registered certification mark should be considered as being covered by the Intertek - Warnock Hersey Listing and Follow-Up Service.

By:


Rick Curkeet, Chief Engineer
Intertek, Building Products Group

Intertek Testing Services NA, Inc.
8431 Murphy Drive, Middleton, WI 53562
Telephone: 608-836-4400 Fax: 608-836-0050
Web: www.intertek-etlsemko.com