

**Intertek**

**ETL SEMKO**

**VERIFICATION OF LISTING**

ISSUED: May 5, 2005

ISSUED TO: **CURRIES Division of AADG, Inc.**  
525 9<sup>th</sup> Street S.E.  
Mason City, IA 50401

REPORT REFERENCES: J98021012-231

This is to certify that representative assemblies of:

**STEEL STIFFENED SWINGING TYPE FIRE DOORS, MODEL 857  
[TWO (2) INCH NOMINAL DOOR THICKNESS]**

have been investigated by Intertek-Warnock Hersey and have been found to be in compliance with the standard(s) indicated on this certificate:

Standards:

UL 10C (1998) "Standard for Positive Pressure Fire Tests of Door Assemblies"  
UBC 7-2-1997 (Part 1) "Fire Tests of Door Assemblies"  
BS 476  
NFPA 252-1995  
UL 10B (1997)  
ASTM E152-81a  
CAN4-S104-1980 (R1985)

Additional Information:

14 or 12 gauge 4'0" x 8'0" single swing doors rated up to and including 3 hours. **No intumescent material required.**

Listed mortise or cylindrical locks and rim or mortise panic devices may be used. 24" x 24" louvers and 48" x 48" metal kick plates may be used. Curries or listed vision light kits may be installed.

Only those products bearing the Warnock Hersey registered certification mark should be considered as being covered by the Intertek – Warnock Hersey Listing and Follow-Up Service.

By:

  
Rick Curkeet, Chief Engineer  
Intertek, Building Products Group

**Intertek Testing Services NA, Inc.**  
8431 Murphy Drive, Middleton, WI 53562  
Telephone: 608-836-4400 Fax: 608-836-0050  
Web: [www.intertek-etlsemko.com](http://www.intertek-etlsemko.com)