

VERIFICATION OF LISTING

ISSUED: May 5, 2005

ISSUED TO: **CURRIES Division of AADG, Inc.**
525 9th Street S.E.
Mason City, IA 50401

REPORT REFERENCES: J99018856-231

This is to certify that representative assemblies of:

FIRE DRYWALL COMPRESSION ANCHOR FRAMES

have been investigated by Intertek-Warnock Hersey and have been found to be in compliance with the standard(s) indicated on this certificate:

Standards:

UL 10C (1998) "Standard for Positive Pressure Fire Tests of Door Assemblies"
UBC 7-2-1997 (Part 1) "Fire Tests of Door Assemblies"
BS 476
NFPA 252-1999
UL 10B (1997)
ASTM E152-81a
CAN4-S104-1980 (R1985)

Additional Information:

14 and 16 gauge Fire Door Frames in drywall walls.

Maximum Door Opening Size:


Single: 48" x 108"

Pairs: 96" x 84" or 84" x 108"

Each frame jamb member must have a compression anchor and a base anchor screw hole in both faces. An anchor suitable for anchoring the frame to a wood or steel stud may be substituted for the base anchor screw holes.

Only those products bearing the Warnock Hersey registered certification mark should be considered as being covered by the Intertek – Warnock Hersey Listing and Follow-Up Service.

By:



Rick Curkeet, Chief Engineer
Intertek, Building Products Group