

VERIFICATION OF LISTING

ISSUED: May 5, 2005

ISSUED TO: **CURRIES Division of AADG, Inc.**
 525 9th Street S.E.
 Mason City, IA 50401

**Intertek/Warnock Hersey
 Neutral Pressure Door Glazing Chart For Use in CURRIES Doors**

GLASS TYPE, BRAND OR DESCRIPTION	RATING	MAX EXPOSED AREA SQ. IN.	MAX WIDTH INCHES	MAX HEIGHT INCHES	GLASS THICKNESS INCHES	MIN. STOP HEIGHT INCHES	MIN. POCKET WIDTH INCHES
Listed Wire Glass	20 min w/o hose	2294	35-13/16	83-5/8	1/4	5/8	3/8
Listed Wire Glass	20 & 45 minute	1296	36	54	1/4	5/8	3/8
Listed Wire Glass	90 minute	100 per leaf	12	33	1/4	5/8	3/8
Central/Asahi or Pilkington Wire glass with Pemko FG3000	20 & 45 minute	2856	34	84	1/4	5/8	7/16
Central/Asahi or Pilkington Wire glass with Pemko FG3000	60 & 90 minute	552 per lite 2204 per leaf	12	46	1/4	5/8	7/16
Firelite, Firelite Plus, or Firelite NT (Technical Glass)	20 min w/o hose	2835	35	81	See Note 1	5/8	See Note 1
Firelite, Firelite Plus, or Firelite NT (Technical Glass)	20, 45, & 60 minute	1296	36	54	See Note 1	5/8	See Note 1
Firelite, Firelite Plus, or Firelite NT (Technical Glass)	90 minute	1296 per leaf	24	54	See Note 1	5/8	See Note 1
Firelite, Firelite Plus, or Firelite NT (Technical Glass)	90 minute	1296 per leaf	36	36	See Note 1	5/8	See Note 1

Note 1: Firelite and Firelite NT are 3/16" thick, 3/8" minimum pocket width

Note 2: All glass areas are per vision light, unless otherwise indicated. Multiple vision lights are allowed.