

VERIFICATION OF LISTING

ISSUED: May 5, 2005

ISSUED TO: **CURRIES Division of AADG, Inc.**
525 9th Street S.E.
Mason City, IA 50401

REPORT REFERENCES: J98033193-231

This is to certify that representative assemblies of:

FIRE DOOR FRAMES

have been investigated by Intertek-Warnock Hersey and have been found to be in compliance with the standard(s) indicated on this certificate:

Standards:

UL 10C (1998) "Standard for Positive Pressure Fire Tests of Door Assemblies"
UBC 7-2-1997 (Part 1) "Fire Tests of Door Assemblies"
BS 476
NFPA 252-1995
UL 10B (1997)
ASTM E152-81a
CAN4-S104-1980 (R1985)

Additional Information:


12, 14, and 16 gauge Fire Door Frames in masonry walls having a maximum overall size of 8'0" x 10'0" are rated up to and including 3 hours. 12, 14, and 16 gauge Fire Door Frames in drywall walls having a maximum overall size of 8'0" wide by 10'0" tall are rated up to and including 1-1/2 hours.

18 gauge Fire Door Frames in masonry or drywall walls having a maximum overall size of 8'0" wide x 8'0" high are rated up to, and including, 1-1/2 hours.

Frames may be of welded or KD construction. Pairs of doors may be installed swinging the same direction or the opposite direction. Frames must be anchored in accordance with CURRIES procedure files. This certification does not include drywall slip-on frames that incorporate a compression type anchoring system. **No intumescent material required.**

Only those products bearing the Warnock Hersey registered certification mark should be considered as being covered by the Intertek – Warnock Hersey Listing and Follow-Up Service.

By:


Rick Curkeet, Chief Engineer
Intertek, Building Products Group