

Intertek

ETL SEMKO

VERIFICATION OF LISTING

ISSUED: May 5, 2005

ISSUED TO: **CURRIES Division of AADG, Inc.**
525 9th Street S.E.
Mason City, IA 50401

REPORT REFERENCES: J99006003-231

This is to certify that representative assemblies of:

FIRE WINDOW FRAMES

have been investigated by Intertek-Warnock Hersey and have been found to be in compliance with the standard(s) indicated on this certificate:

Standards:

UL 10C (1998) "Standard for Positive Pressure Fire Tests of Door Assemblies"
UBC 7-2-1997 (Part 1) "Fire Tests of Door Assemblies"
BS 476
UL 9
NFPA 257-2000
CAN4-S104-1980 (R1985)


Additional Information:

12, 14, and 16 gauge Fire window Frames are rated up to and including 1 hour.

Maximum overall size of 13'6" wide by 12'0" high masonry walls;
Maximum overall size of 11'4" wide by 10'0" high drywall walls **with** a non-combustible sill;
Maximum overall size of 10'0" wide by 5'1" high masonry walls **without** a non-combustible sill. (A non-combustible sill is defined in NFPA 220 "Standard on Type of Building Construction").

Only those products bearing the Warnock Hersey registered certification mark should be considered as being covered by the Intertek – Warnock Hersey Listing and Follow-Up Service.

By:



Rick Curkeet, Chief Engineer
Intertek, Building Products Group

Intertek Testing Services NA, Inc.
8431 Murphy Drive, Middleton, WI 53562
Telephone: 608-836-4400 Fax: 608-836-0050
Web: www.intertek-etlsemko.com