

Intertek

ETL SEMKO

VERIFICATION OF LISTING

ISSUED: May 5, 2005

ISSUED TO: **CURRIES Division of AADG, Inc.**
525 9th Street S.E.
Mason City, IA 50401

REPORT REFERENCES: J99006003-231

This is to certify that representative assemblies of:

TRANSOM LIGHT AND SIDELIGHT FRAMES

have been investigated by Intertek-Warnock Hersey and have been found to be in compliance with the standard(s) indicated on this certificate:

Standards:

UL 10C, "Standard for Positive Pressure Fire Tests of Door Assemblies"

UBC 7-2-1997 (Part 1) "Fire Tests of Door Assemblies"

UI 9

BS 476

NFPA 257

UL 10B


CAN4-S104

Additional Information:

12, 14, and 16 gauge Transom Light and Sidelight Frames in masonry walls having a maximum overall size of 13'6" wide by 12'0" high, and in drywall walls having a maximum overall size of 12'0" wide by 11'7-1/2" high, are rated up to and including 1 hour.

Only those products bearing the Warnock Hersey registered certification mark should be considered as being covered by the Intertek – Warnock Hersey Listing and Follow-Up Service.

By:


Rick Curkeet, Chief Engineer
Intertek, Building Products Group

Intertek Testing Services NA, Inc.
8431 Murphy Drive, Middleton, WI 53562
Telephone: 608-836-4400 Fax: 608-836-0050
Web: www.intertek-etlsemko.com